



Dear Valued Customers,

In March 2022, Coweta County Water and Sewerage Authority (CCWSA) received a notice of violation from the Georgia EPD regarding an exceedance of the TTHM Maximum Contaminant Level (MCL). The TTHM MCL is set at 80 parts per billion and CCWSA recorded a Locational Running Annual Average of 81 parts per billion for Site # 502 (Haynes Rd) during the last sampling quarter of 2021. Areas where TTHMs can form are stretches of dead-end lines where there is little to no usage causing the water to age and TTHMs to form. While CCWSA is required to notify all 29,000+ customers, the actual number of customers affected by the MCL exceedance is confined to a very small number of customers that reside in the southern part of the CCWSA system on Haynes Rd.

Since receiving the notice of violation from GA EPD, CCWSA has worked aggressively to return to compliance. CCWSA has increased sampling frequency from the state required quarterly sampling to monthly sampling. The results from the latest sampling event at Haynes Rd were under 35 parts per billion. Additional actions taken by CCWSA include continuing to flush the affected area to reduce water aging and investing in Smart Flushing technology. A Smart Flushing device will allow the affected area to be flushed any time the device detects the chlorine residual has dropped below a value set by CCWSA. All the above-mentioned actions taken will allow CCWSA to return to compliance and will help prevent noncompliance moving forward.

If you have questions or concerns, please contact Michael Ballew at (678) 877-0778.

Regards,

Michael Ballew – Plant Superintendent BT Brown WTP