

Krebs Engineering, Inc.
15 LaGrange Street
Newnan, GA 30263
470-724-5050
June 1, 2022

ADDENDUM NO. 01

CONTRACT NO.: 21508.2 – UV Disinfection Equipment
OWNER: Coweta County Water & Sewerage Authority
PROJECT: Shenandoah WWTF – UV Disinfection Equipment RFP

BID DATE: June 15, 2022
TO: ALL PROSPECTIVE CONTRACTORS AND SUPPLIERS

The changes, modifications, and/or additions covered by and set forth in this Addendum No. 01 shall become part of and be incorporated in the Contract Documents for the above referenced project:

CLARIFICATIONS:

AD1.1 **Question:** Section 44 44 16 – 2.2 H. 1 – please confirm the MSL of 800.50 is upstream or downstream of the UV system? The spec language references “the upstream water shall not exceed elevation 800.50...” The example layout drawing shows elevation 800.50 on the downstream side of the UV system.

Krebs Response: The specification language is correct stating that “the upstream water level shall not exceed elevation 800.50 above MSL.” This elevation is also shown in the included drawing C11-03.

AD1.2 **Question:** Please provide an electronic version of the Lifecycle Evaluation Form.


Krebs Response: Life Cycle Cost Spreadsheet is included as an attachment to this addendum.

AD1.3 **Question:** Could you clarify if the forms in Appendix D are to be supplied with the bid? There is a requirement for a bid bond in that appendix and a large number of forms all of which appear to be for the Owner to fill out and submit to the State. Are we required to supply a bid bond with the proposal.

Krebs Response: Appendix D – GEFA Supplemental General Conditions is provided for reference that the overall project will be a GEFA funded project, including the purchase of equipment. The proposing equipment manufacturers are not required to complete Appendix D at this time, nor are the manufacturers required to provide a bid bond.

This Addendum No. 01 shall be attached to the front of your set of specifications and made a part of the Contract Documents. Receipt of this Addendum No. 01 shall be acknowledged on of the Proposal Form.

Krebs Engineering, Inc.

By  _____
Jarred M. Jackson, PE
Senior Associate

THIS IS THE LAST PAGE

Attachments to Addendum No. 01 preceding this page:

A total of _____ pages or sheets of drawings (including this page) have been included in Addendum No. 01.

General Contractors are requested to return this page as an acknowledgement that you have received this Addendum by _____. This will NOT be mailed. A copy of this Addendum may be picked up at the office of the _____.

Return to Krebs Engineering, Inc. by email to Jarred.Jackson@krebseng.com.

Received By _____

Contractor _____

Date _____